

**CHARACTERISATION OF
POWER GENERATION OPTIONS
FOR THE 21ST CENTURY**
Report on behalf of Macro task E1

P. Lako
A.J. Seebregts

Preface

ECN Policy Studies has carried out the present study under a contract of the European Union, DG XII, the Dutch Ministry of Economic Affairs, and the Dutch Ministry of Education, Culture, and Science. The ECN project number is 77119.

Abstract

This report gives an overview of power generation options in the MARKAL model for Western Europe. This model has been used for the evaluation of the economic potential of fusion power in Western Europe in the 21st century. Such an evaluation was part of the so-called SERF programme of the European Union (DG XII). The economic potential of fusion power, as analysed by ECN Policy Studies, is reported in the macro task SE0, which addresses long term scenarios. The present report describes the power generation options included in the model of the Western European energy system, on behalf of macro task E1, cost of fusion. The cost data are expressed as ECU of the year 1995.

CONTENTS

SUMMARY	5
1. INTRODUCTION	7
2. FISSION AND FUSION POWER	9
2.1 Introduction	9
2.2 Fission power	9
2.3 Fusion power	10
3. FOSSIL FUEL BASED POWER	12
3.1 Introduction	12
3.2 Coal-fired power	12
3.3 Oil- and gas-fired power	13
4. RENEWABLE POWER	14
4.1 Introduction	14
4.2 Hydro power	14
4.3 Wind energy	14
4.4 Solar energy	15
4.5 Remaining renewable power options	15
5. OVERVIEW OF POWER GENERATION COSTS	16
ANNEX A MARKAL DATA OF POWER GENERATION OPTIONS	18
ANNEX B BACKGROUND DATA ON IMPORTANT POWER GENERATION OPTIONS	40
ANNEX C LIST OF ENERGY CARRIERS/ MATERIALS TECHNOLOGIES AND DEMAND CATEGORIES IN MARKAL EUROPE 2.0	46
REFERENCES	56

SUMMARY

This report contains data on power generation options used in the MARKAL model for Western Europe MARKAL-EUROPE 2.0. The MARKAL model has been used for the evaluation of the economic potential of fusion power in the 21st century. This overview of the power generation options in the MARKAL model is part of macro task E1 (cost of fusion). Macro task E1 is one of the five macro tasks in the framework of socio-economic studies of the so-called SERF programme (Socio Economic Research on Fusion) on behalf of the European Union (DGXII). The economic potential of fusion power, as analysed by ECN Policy Studies [1], is reported in the macro task SE0, which addresses long term scenarios. Investment costs are presented in ECU of 1995 and are based on a discount rate of 5% (a higher discount rate means a higher investment cost due to interest during construction).

In Chapter 2 fission and fusion power are presented in some detail, notably:

- Light Water Reactor (LWR, fission power),
- some commercial fusion power plant assumed available from 2050 on.

Chapter 3 presents a number of fossil fuel based power generation options, such as:

- pulverised coal-fired power,
- lignite-fired power,
- oil-fired power,
- gas-fired power,
- Conventional technologies, and advanced fossil fuel based options are considered.

Chapter 4 contains renewable power options: hydro power, wind power, solar power, wave power, tidal power, geothermal power, and waste-to-energy power plants. At last, comprehensive figures on power generation costs are presented in Chapter 5.

1. INTRODUCTION

This report contains tables with data on power generation technologies used in the MARKAL model for Western Europe which has been made used for the evaluation of the potential of fusion power in the 21st century. The reference discount rate is 5%, although two comprehensive figures of generation costs are presented based on a discount rate of 8%. The tables presented have been derived from a spreadsheet which includes similar investment cost data for discount rates of 5, 8, and 10%, in addition to a similar figure based on a discount rate of 5%. All power generation options with a construction schedule of more than one year show differences in investment costs as a function of the discount rate used, because of Interest During Construction (IDC). The reference currency is the ECU of year 1995.

2. FISSION AND FUSION POWER

2.1 Introduction

Fission power as we know it today delivers about 17% of the electricity generated in the world. Most of the nuclear power plants have been built in the western world. There are a few options for fission power, the most well known being the Light Water Reactor (LWR).

Fusion power is a long term power generation option with characteristics which are very different from fission power:

- Little long living radioactive waste: decommissioning waste of fusion reactors is only a fraction of the long living radioactive waste of fission reactors.
- No probability of core melt accidents or other serious accidents which can occur with fission power plants.
- A virtually inexhaustible and CO₂ free energy source.

Fusion power is in the R&D stage today. It is envisaged that fusion power could enter the demonstration stage around 2020-2030, and the commercial stage around 2050.

Data on the LWR are presented in Section 2.2. Section 2.3 contains data on a commercial fusion power plant, assumed to become available around 2050.

2.2 Fission power

About 30% of the Western European power production is based on fission power. Western European power generating companies operate almost exclusively LWRs, with as a main exception gas-cooled reactors in the UK (relatively small Magnox reactors as well as larger AGRs, Advanced Gas-cooled Reactors). However, also the UK has turned to the LWR since their first reactor of this kind, Sizewell-B. Gas-cooled reactors (AGRs) are regarded as less economic than LWRs.

Light Water Reactors (LWRs) are Pressurised Water Reactors (PWRs) or Boiling Water Reactors (BWRs). An alternative to the LWR would be the helium-cooled High Temperature Reactor (HTR). Because of their high operating temperature, enabled by the coolant helium, their low power density, and specific fuel design, HTRs are rather efficient compared to LWRs with respect to thermal efficiency (45-50% for HTRs, 33-35% for LWRs). What is more, HTRs have a very large safety margin and are far from prone to loss-of-coolant accidents and other possibly dangerous accidents. Large demonstration HTRs of some 300 MWe have been built and operated in Germany and the US. However, their operating experience proved to be not very favourable. Modular HTRs with capacities of 80 to 250 MWe have been proposed in the past ten years. The South African utility Eskom has decided to build a demonstration HTR of 110 MWe (265 MWth), based on the German 'pebble-bed' design. In the framework of the evaluation of fusion power it was deemed not appropriate to incorporate an HTR in the model of the Western European energy system, as there is no clear evidence that HTRs would be favoured and would result in lower power generation costs than LWRs.

Another alternative to the LWR would be a liquid-metal-cooled Fast Breeder Reactor (FBR). This reactor type is very efficient with respect to the resource uranium (some 60 times more efficient

than the LWR). However, the liquid-metal Fast Breeder Reactor has safety characteristics which are less favourable than those of LWRs. Moreover, they need reprocessing of uranium and plutonium on a large scale, which induces risks of proliferation. Operating experience with demonstration FBRs has been unfavourable. Because there seems to be insufficient public acceptance for an FBR, it was deemed not appropriate to incorporate it in the Western European energy model.

The LWR is the only fission option considered in the evaluation of the potential of fusion power in Western Europe. Annex B, Table B1, shows investment costs of three German Konvoi plants (PWRs), commissioned around 1988, as well as one N4 (PWR, planned but never been built in Belgium). Investment costs range from ECU 1870/kW to ECU 2200/kW [2, 3]. These figures include the first core and interest during construction (IDC), based on a discount rate of 5%. A representative investment cost figure is ECU 2060/kW (Table A.1), almost the same as the investment cost of the EPR¹ presented in [4] (a contribution of FZ Jülich to SEO). Operation and maintenance costs, including several insurance costs, are estimated at ECU 46/kW/year¹ [5, 6].

2.3 Fusion power

Gilli and Kurz give a detailed assessment [7] of the economics of fusion power as a contribution to macro task SEO. As this study became available in an early stage of the SERF programme, the results are used as reference. Other cost estimates are used in the sensitivity analysis. The study is based on analysis of the stage of development and demonstration on the one hand, and the stage of commercialisation on the other hand. Before the commercial stage, investment costs come down rapidly. Most of the cost reduction is realised in the so-called fusion core. The cost of the so-called Balance of Plant (BOP) does not show similar opportunities for cost reduction. After having reached a competitive cost level, learning is related to the production of increasing numbers of (larger) identical fusion power plants rather than to major changes of the technology.

The investment cost of a twin 1500 MW fusion power plant is derived from the corresponding cost of a single 1000 MW fusion power plant, taking into account cost degression with unit size and cost degression with number of units at one site. Because of these two degression factors, the investment cost of a twin 1500 MW fusion power plant is 33% lower than that of a single 1000 MW plant, according to Gilli and Kurz [7].

Annex B, Table B2, presents the investment costs of a twin 1500 MW fusion power plant, which is assumed to be available from 2070 on. In 2070 the specific investment costs are ECU 3210/kWe. In the year 2100 costs have come down to ECU 2980/kWe. Table A.2 shows the investment cost over time, as well as the operation and maintenance costs, including replacement costs of diverter, blanket, and first wall.

¹ In [4] investment costs of the European Pressurized Water Reactor (EPR) are estimated at ECU 1600/kW in ECU's 1990, which is equal to ECU 1900/kW in ECU's 1995.

3. FOSSIL FUEL BASED POWER

3.1 Introduction

Coal is a main fuel for power generation in Western Europe. Natural gas is used for industrial Combined Heat and Power (CHP), district heating (the Netherlands), sometimes for base-load power production and for peak load gas turbines. The model of the Western European energy system includes a number of fossil fuel based power generation options. Section 3.2 addresses coal-fired options, and Section 3.3 addresses oil-fired and gas-fired options.

3.2 Coal-fired power

Annex B, Table B3, presents investment costs of German coal-fired power plants [8, 9]. Contribution [4] of FZ Jülich to SE0 gives similar data. Until recently, coal-fired power plants in Europe were based on steam parameters up to 540 °C and 250 bar. Supercritical live steam conditions of 620 °C and 300 bar, single reheat with 600 °C and 55 bar and very low condenser pressures (0.036 bar) enable efficiencies beyond 45% [4]. The level of investment cost assumed here is ECU 1190/kWe (Table A.3). Investment cost of desulphurisation and low-NO_x burners are included. The net generating efficiency is assumed to increase from 46% in 2000 to 50% in 2030.

Also Integrated Gasification Combined Cycle (IGCC) is considered (Table A.4):

- investment cost ECU 1450/kW in 2000, decreasing to ECU 1290/kW in 2040,
- net generating efficiency increasing from 48% in 2000 to 52% in 2040.

These assumptions are mainly based on the FZ Jülich study [4].

Alternatively, IGCC with CO₂ capture and sequestration could be applied (Table A.5):

- investment cost ECU 1820/kW in 2010, decreasing to ECU 1710/kW in 2040,
- net generating efficiency increasing from 43% in 2010 to 45.5% in 2040.

This technology has to be developed. Parameters have been derived from e.g. [10].

Additionally two very advanced coal-fired options are considered, viz. IGCC combined with SOFC, Solid Oxide Fuel Cells (Table A.6) and the same option in combination with CO₂ separation and sequestration (Table A.7). Investment costs and operation and maintenance costs of these options are quite uncertain. However, their inclusion in the data base gives fossil-fired power sufficient room for improvement, both in efficiency and in CO₂ reduction terms. Table A.8 presents a less advanced option, viz. Fluidised Bed Combustion (FBC) based on hard coal. Atmospheric FBC power plants of some 100-200 MWe are mainly used for industrial CHP and district heating.

At last, we address lignite-fired power plants. Generally, they are based on live steam parameters of 580 °C and 260 bar. Their net efficiency is about 43% (study FZ Jülich [4]). Optimised technology can be improved by integrated lignite drying in a fluidised bed with utilisation of the condensation heat of the water vapour. Annex B, Table B3, shows characteristics of lignite-fired power plants [11, 12, 13, 14, 15] and data from FZ Jülich [4]. Table A.9 presents data on advanced lignite-fired power plants as a function of time.

3.3 Oil- and gas-fired power

Oil fired power options, based on either conventional steam boilers or IGCC, are presented in Tables A.10 and A.11 respectively. Investment costs of IGCCs based on residual oil are somewhat lower than those of IGCCs based on hard coal.

Tables A.12 to A.18 show a range of gas-fired options, notably:

- combined cycle plant (for district heating or power only),
- combined cycle plant combined with SOFC (fuel cells) for district heating,
- gas turbine peaking plant,
- gas turbine plant for industrial CHP (Combined Heat and Power),
- combined cycle plant for industrial CHP,
- gas engine for total energy application,
- Heron gas turbine with SOFC (fuel cells) for total energy application.

These options are mainly based on earlier studies of ECN Policy Studies [16, 17], and on the FZ Jülich study [4].

4. RENEWABLE POWER

4.1 Introduction

Hydro power is a commercial renewable power option. Wind turbines on land and near-shore have become established technologies, whereas offshore wind power is in the stage of demonstration. Commercialisation depends on sufficient cost reduction in the next decades. Solar power is generally based on photovoltaic energy (PV). The model includes several PV options, as well as solar thermal power. At last wave energy, tidal energy, geothermal energy, and waste-to-energy power are considered.

For biomass-fuelled power a range of options is available, which have been described in a recent analysis of the CO₂ reduction potential of biomass technologies for the Netherlands [18]. The availability of biomass in Western Europe has been analysed in [19].

4.2 Hydro power

There are several types of hydro power plants, such as reservoir type and run-of-river plants. We assume most of hydro capacity to be of the medium to high head type (reservoir type plants), and a smaller fraction of the low head type (run-of-river plants). Characteristics of these two types of hydro power, based on [16], are shown in Tables A.19 and A.20. Hydro power plants have load factors ranging from 36% to 50%.

4.3 Wind energy

Data on wind energy - onshore (inland and shore), near-shore, offshore - in Western Europe have been updated since 1997 [16]. Characteristics of these categories of wind power are shown in Tables A.21 to A.24. Offshore is divided in two categories: near-shore (less than 10 km from the shore) and offshore. Investment costs of onshore wind turbines are relatively low. Load factors range from 24% for inland windturbines to 36% for offshore windturbines (Tables A.21 and A.24 respectively). The higher load factor of offshore (and near-shore) wind does not offset the higher investment cost, which are ECU 1515/kW for offshore wind versus ECU 820-840/kW for onshore wind in 2040.

The maximum installed capacity potentials of these categories of wind power in Western Europe are as follows:

- onshore wind, inland locations: 33 GW,
- onshore wind, shore locations: 42 GW,
- near-shore wind (distance to shore less than 10 km): 12.5 GW,
- offshore wind (distance to shore 10 km and more): 112.5 GW.

The total maximal installed capacity of wind power in Western Europe in 2100 is thus estimated at 200 GW.

4.4 Solar energy

Photovoltaic power (PV) is an important power generation option (Table A.25 to A.28). Solar thermal power generation is already available, but only applicable in Southern Spain (Table A.29). Besides, solar thermal power seems to be less promising than PV.

The two types of solar PV considered are:

- average of roofs and land at the latitude of Madrid,
- roofs in three regions, from latitude Amsterdam to latitude Lyon, and latitude Malaga.

The average load factor ranges from 10.6% in Northern Europe (latitude Amsterdam) to 19.4% the latitude of Malaga. These data are mainly derived from an earlier (1997) study of ECN Policy Studies [16]. The maximum installed capacity of the four categories are:

- Northern Europe (central UK, IRL, NL, B, northern Germany, DK): 120 GW_p,
- Central Europe (FR, Southern Germany, CH, AU): 180 GW_p,
- Southern Europe (central Spain and Italy): 125 GW_p,
- Latitude Malaga (most southern Spain, Italy, Greece): 50 GW_p.

The total maximum installed capacity of PV in Western Europe is thus estimated at 475 GW. Besides, the potential of solar thermal power plants in Southern Europe is estimated at 5 GW.

4.5 Remaining renewable power options

A rather novel option is wave power, an option with potential in Portugal and Ireland. A device called Archimedes Wave Swing with a capacity of 8 MW per module makes effective use of the energy in long waves on the Atlantic coast. Demonstration will start within a few years. Investment cost is approx. ECU 1600/kW, the annual load factor is 50%. Its potential in Portugal and Ireland is estimated at 4 GW [20] (Table A.29).

Tidal power is largely proven technology. Tidal power schemes have been proposed for the UK (Severn estuary). Investment costs are approx. ECU 1775/kW, with an average load factor of 23%. The Western European potential is estimated at 10 GW. Table A.30 shows their characteristics, based on studies on tidal power in the UK [21, 22].

At last, Tables A.31 and A.32 contain data on geothermal power [23, 24] and waste-to-energy power plants [25], respectively.

5. OVERVIEW OF POWER GENERATION COSTS

Some representative power generation options are exhibited in three figures, showing their power generation costs. Figure 5.1 shows the options selected, with climbing generation costs for the year 2070 and a discount rate of 8%, and based on the fuel prices of scenario MD (Market Drive) [1]. It comes out that fusion power is more expensive than e.g. offshore wind and solar PV at central European latitude (Lyon). It should be noted, however, that generation costs are not fully comparable, as some options like wind and solar power are intermittent options. However, it is a crude way to rank these options with respect to generation costs.




Figure 5.1 Comparison of generation cost of some representative power generation options of the 21st century, fuel prices of scenario MD, discount rate 8%, year 2070

Figure 5.2 shows the generation costs for the year 2100 and a discount rate of 8%, also based on the fuel prices of scenario MD. At last, Figure 5.3 presents the same options for the year 2100 and a discount rate of 5%, based on the fuel prices of scenario RP (Rational Perspective). Note that the prices of natural gas in scenario RP are lower than in case of scenario MD. Further, the technology presumed for gas fired power is the combined cycle power plant.

It comes out that the gap between e.g. fusion power and renewable options like offshore wind and PV at central European latitude becomes rather small towards 2100. Taking into account the intermittent nature of wind and solar energy, it is allowed to generalise that fusion power and new renewables like offshore wind and PV at central European latitudes have generation costs which are of the same order of magnitude.




Figure 5.2 Comparison of generation cost of some representative power generation options of the 21st century, discount rate 8%, year 2100 (scenario MD)




Figure 5.3 Comparison of generation cost of some representative power generation options of the 21st century, discount rate 5%, year 2100 (scenario MD)

ANNEX A MARKAL DATA OF POWER GENERATION OPTIONS

The tables of Annex A contain characteristic data of power generation options. Not all power generation options of the MARKAL model (58) are included, but those included (33) are deemed to be key technologies or representative options.

Table A.1 *Technical economic characteristics of Light Water Reactor (LWR)*

LWR (EN0)		1990	2000	2010	2020	2030	2040	2050	2070	2100
	Life	[×10 year]	4							
	Building schedule	[year]	6							
	Eff	[%]	33.5							
	Load factor	[%]	72.5	75	77.5	80	82.5	85	87.5	87.5
	Total capital cost (1)	[ECU/kWe]	1700							
	IDC (2)	[ECU/kWe]	268							
	First core (3)	[ECU/kWe]	89							
	Decom fund (4)	[ECU/kWe]	29							
	Invcost (1+2+3+4)	[ECU/kWe]	2086	2085	2085	2085	2085	2085	2085	2085
	O&M cost	[ECU/kWe]	46	46	46	46	46	46	46	46
	Resid	[GWe]	80.65	80.59	77.96	32.92	6.28	0	0	0
	Boundlo	[GWe]	118.4	126.7	124	78.99	14.59	8.3		
Scenario Market Drive	Boundup	[GWe]	118.4	126.7	126.7	126.7	114	114	114	101.3
	Ibondup	[GWe/10 year]	37.77	8.305	2.63	45.04	51.75			
Scenario Rational Perspective	Boundup	[GWe]	118.4	126.7	126.7	126.7	107.7	107.7	107.7	88.7
	Ibondup	[GWe/10 year]	37.77	8.305	2.63	45.04	45.41			

Life = economic lifetime

IDC = Interest during construction

O&M = operation and maintenance cost

Eff = efficiency

Invcost = investment cost

Varom = variable operation and maintenance cost

Ibondup = maximum investment in new capacity per period

Resid = residual capacity

Table A.2 *Technical economic characteristics of Fusion Power*

Fusion power (EN1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	6.25								
Start	[year]	2030								
Eff	[%]	46.3								
Load factor	[%]					67.5	70	72.5	75	75
Total capital cost (1)	[ECU/kWe]	2576								
IDC (2)	[ECU/kWe]	424								
Invcost (1+2)	[ECU/kWe]	3000			9378	8279		6080	3408	3000
O&M cost	[ECU/kWe]	184			430	377		270	190	184
Boundup	[GWe]					1	2.5	7	60	200
Ibondup	[GWe/10 year]					1	1.5	4.5	31.5	69

Note: Maximum of fusion power in 2070: 58.9 GW, and in 2100: 157.5 GW.

Table A.3 *Technical economic characteristics of Advanced Pulverised Coal Fired Power Plant*

Advanced pulverised fired power plant (EC4)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3.25								
Start	[year]	2000								
Eff	[%]		46	48	49	50	50	50	50	50
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1100								
IDC (2)	[ECU/kWe]	91								
Invcost (1+2)	[ECU/kWe]	1191	1190	1190	1190	1190	1190	1190	1190	1190
O&M cost	[ECU/kWe]	37	37	37	37	37	37	37	37	37
Varom	[ECU/GJe]	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26

Table A.4 *Technical economic characteristics of Integrated Gasification Combined Cycle (IGCC)*

Integrated gasification combined cycle (EC5)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3								
Start	[year]	2000								
Eff	[%]		48	49	50	51	52	52	52	52
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1202								
IDC (2)	[ECU/kWe]	91								
Invcost (1+2)	[ECU/kWe]	1293	1450	1360	1320	1300	1290	1290	1290	1290
O&M cost	[ECU/kWe]	31	31	31	31	31	31	31	31	31
Varom	[ECU/GJe]	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3

 Table A.5 *Technical economic characteristics of IGCC with Water Gas Shift Conversion and CO₂ Sequestration*

IGCC, water gas shift conversion and CO ₂ sequestration (EC5+)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3.5								
Start	[year]	2010								
Eff	[%]			42.88	43.75	44.63	45.5	45.5	45.5	45.5
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1566								
IDC (2)	[ECU/kWe]	140								
Invcost (1+2)	[ECU/kWe]	1706		1820	1755	1725	1710	1710	1710	1710
O&M cost	[ECU/kWe]	43		44	43	43	43	43	43	43
Varom	[ECU/GJe]	0.38		0.38	0.38	0.38	0.38	0.38	0.38	0.38

Table A.6 *Technical economic characteristics of Integrated Coal Gasification SOFC Power Plant*

Integrated coal gasification SOFC power plant (EC8)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3								
Start	[year]	2020								
Eff	[%]				53	54.5	56	57.5	57.5	57.5
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1286								
IDC (2)	[ECU/kWe]	98								
Invcost (1+2)	[ECU/kWe]	1384			1490	1430	1400	1385	1385	1385
O&M cost	[ECU/kWe]	43			47	45	44	43	43	43
Varom	[ECU/GJe]	1.7			1.7	1.7	1.7	1.7	1.7	1.7

Table A.7 *Technical economic characteristics of IG SOFC Power Plant with CO₂ Separation and Sequestration*

IG SOFC power plant, CO ₂ separation and sequestration (EC8+)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3.5								
Start	[year]	2030								
Eff	[%]					49.05	50.4	51.75	51.75	51.75
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1585								
IDC (2)	[ECU/kWe]	141								
Invcost (1+2)	[ECU/kWe]	1726				1785	1745	1725	1725	1725
O&M cost	[ECU/kWe]	53				56	54.5	53	53	53
Varom	[ECU/GJe]	1.8				1.8	1.8	1.8	1.8	1.8

Table A.8 *Technical economic characteristics of Coal Fluidised Bed Combustion Combined Heat and Power Plant*

Coal FBC CHP plant (ECA)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3								
Start	[year]									
Eff										
Electric		11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5
Thermal		75	75	75	75	75	75	75	75	75
Load factor	[%]	80								
Total capital cost (1)	[ECU/kWe]	2788								
IDC (2)	[ECU/kWe]	212								
Invcost (1+2)	[ECU/kWe]	3000	3000	3000	3000	3000	3000	3000	3000	3000
O&M cost	[ECU/kWe]	120	120	120	120	120	120	120	120	120

 Table A.9 *Technical economic characteristics of Advanced Lignite Fired Power Plant*

Advanced lignite fired power plant (EC6)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	4								
Start	[year]	2000								
Eff	[%]		43	46	47.5	49	49	49	49	49
Load factor	[%]	80								
Total capital cost (1)	[ECU/kWe]	1185								
IDC (2)	[ECU/kWe]	121								
Decomfund (3)	[ECU/kWe]	7								
Invcost (1+2)	[ECU/kWe]	1314	1265	1290	1315	1315	1315	1315	1315	1315
O&M cost	[ECU/kWe]	81	75	78	81	81	81	81	81	81
Varom	[ECU/GJe]	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60	0.60

 Table A.10 *Technical economic characteristics of Advanced Oil Fired Power Plant*

Advanced oil fired power plant (ED1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3.5								
Start	[year]	2000								
Eff	[%]	45	45	45	45	45	45	45	45	45
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	721								
IDC (2)	[ECU/kWe]	64								
Invcost (1+2)	[ECU/kWe]	785	785	785	785	785	785	785	785	785
O&M cost	[ECU/kWe]	24	24	24	24	24	24	24	24	24
Varom	[ECU/GJe]	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26

Table A.11 *Technical economic characteristics of Oil Fired IGCC*

Oil fired IGCC (ED1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	3								
Start	[year]	1990								
Eff	[%]	44.5	46	47.5	49	50.5	52	52	52	52
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	1322								
IDC (2)	[ECU/kWe]	100								
Invcost (1+2)	[ECU/kWe]	1423	1850	1610	1500	1450	1425	1425	1425	1425
O&M cost	[ECU/kWe]	29	29	29	29	29	29	29	29	29
Varom	[ECU/GJe]	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1

Table A.12 *Technical economic characteristics of Gas Fired Combined Cycle Power Plant*

Gas fired combined cycle power plant (EG3)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	2.5								
Start	[year]	2000								
Eff	[%]		56	57	58	59	60	60	60	60
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	508								
IDC (2)	[ECU/kWe]	32								
Invcost (1+2)	[ECU/kWe]	540	670	540	540	540	540	540	540	540
O&M cost	[ECU/kWe]	10	10	10	10	10	10	10	10	10
Varom	[ECU/GJe]	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45

 Table A.13 *Technical economic characteristics of Combined Cycle SOFC Power Plant*

Combined cycle SOFC power plant (EG4)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	2.5								
Start	[year]	2000								
Eff	[%]			64	66	68	70	70	70	70
Load factor	[%]	75								
Total capital cost (1)	[ECU/kWe]	817								
IDC (2)	[ECU/kWe]	51								
Invcost (1+2)	[ECU/kWe]	869		1050	950	905	880	870	870	870
O&M cost	[ECU/kWe]	24		27	26	25	24	24	24	24
Varom	[ECU/GJe]	1.4		1.4	1.4	1.4	1.4	1.4	1.4	1.4

Table A.14 *Technical economic characteristics of Gas Turbine Peaking Plant*

Gas turbine peaking plant (EG1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	1.5								
Start	[year]									
Eff	[%]	33	34.5	36	37.5	39	39	39	39	39
Load factor	[%]	25								
Total capital cost (1)	[ECU/kWe]	365								
IDC (2)	[ECU/kWe]	14								
Invcost (1+2)	[ECU/kWe]	379	380	380	380	380	380	380	380	380
O&M cost	[ECU/kWe]	11	11	11	11	11	11	11	11	11
Varom	[ECU/GJe]	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

Table A.15 *Technical economic characteristics of Gas Turbine Combined Heat and Power Plant*

Gas turbine CHP plant (EGD)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	1.5								
Start	[year]	2000								
Eff										
Electric	[%]		33	34	35	36	37	37	37	37
Thermal	[%]		47	46	45	44	43	43	43	43
Load factor	[%]	80								
Total capital cost (1)	[ECU/kWe]	733								
IDC (2)	[ECU/kWe]	27								
Invcost (1+2)	[ECU/kWe]	760	760	760	760	760	760	760	760	760
O&M cost	[ECU/kWe]	11	11	11	11	11	11	11	11	11
Varom	[ECU/GJe]	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

Table A.16 *Technical economic characteristics of Combined Cycle Combined Heat and Power Plant*

Combined cycle CHP plant (EGE)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	2.5								
Start	[year]	2000								
Eff										
Electric	[%]		43	44	45	46	47	47	47	47
Thermal	[%]		29	28	27	26	25	25	25	25
Load factor	[%]	80								
Total capital cost (1)	[ECU/kWe]	558								
IDC (2)	[ECU/kWe]	35								
Invcost (1+2)	[ECU/kWe]	593	590	590	590	590	590	590	590	590
O&M cost	[ECU/kWe]	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5
Varom	[ECU/GJe]	0.55	0.55	0.55	0.55	0.55	0.55	0.55	0.55	0.55

 Table A.17 *Technical economic characteristics of Gas Engine Total Energy*

Gas engine total energy (EGF)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	1.5								
Building schedule	[year]	0.25								
Start	[year]	2000								
Eff										
Electric	[%]		36	37	38	39	39	39	39	39
Thermal	[%]		52.5	52	51.5	51	51	51	51	51
Load factor	[%]	0.5								
Invcost (1+2)	[ECU/kWe]	950	950	950	950	950	950	950	950	950
O&M cost	[ECU/kWe]	24	24	24	24	24	24	24	24	24
Varom	[ECU/GJe]	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Table A.18 *Technical economic characteristics of Heron Turbine SOFC (Total Energy)*

Heron turbine SOFC (EGG)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	2.5								
Building schedule	[year]	0.4								
Start	[year]	2000								
Eff										
Electric	[%]		55	25.7	59	60	60	60	60	60
Thermal	[%]		25	22.5	21	20	20	20	20	20
Load factor	[%]	50								
Invcost (1+2)	[ECU/kWe]	1010	1325	1135	1050	1010	1010	1010	1010	1010
O&M cost	[ECU/kWe]	34	38	36	34	34	34	34	34	34
Varom	[ECU/GJe]	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4

Table A.19 *Technical economic characteristics of Medium and High Head Hydro Power*

Medium and high head hydro power (EH0)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	7.5								
Building schedule	[year]	7								
Start	[year]									
Load factor	[%]	36								
Total capital cost (1)	[ECU/kWe]	1442								
IDC (2)	[ECU/kWe]	269								
Invcost (1+2)	[ECU/kWe]	1711	1710	1710	1710	1710	1710	1710	1710	1710
O&M cost	[ECU/kWe]	38	38	38	38	38	38	38	38	38

Table A.20 *Technical economic characteristics of Low Head Hydro Power*

Low head hydro power (EH1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	7.5								
Building schedule	[year]	5								
Start	[year]									
Load factor	[%]	50								
Total capital cost (1)	[ECU/kWe]	2404								
IDC (2)	[ECU/kWe]	312								
Invcost (1+2)	[ECU/kWe]	2716	2715	2715	2715	2715	2715	2715	2715	2715
O&M cost	[ECU/kWe]	38	38	38	38	38	38	38	38	38

Table A.21 *Technical economic characteristics of Onshore Wind Energy, Inland Location*

Onshore wind energy inland location (EW5)		1990	2000	2010	2020	2030	2040	2050	2070	2100	
Life	[×10 year]	3									
Building schedule	[year]	0.25									
Start	[year]										
Load factor	[%]	24	24	24	24	24	24	24	24	24	24
Invcost	[ECU/kWe]	841	1150	1000	865	840	840	840	840	840	840
O&M costs	[ECU/kWe]	17	23	20	17	17	17	17	17	17	17
Resid	[GWe]	0.022	0.011	0	0	0	0	0	0	0	0
Boundlo	[GWe]	0.065	2	3	3	3	3	3	3	3	3
Boundup	[GWe]	0.066	2.15	5.5	10.3	15.1	20	24.9	33	33	33
Ibondup	[GWe/10 year]	0.044	2.1	3.3	4.9	6.9	8.2	9.8	11.5	11.5	11.5

Table A.22 *Technical economic characteristics of Onshore Wind Energy, Shore Location*

Onshore wind energy shore location (EW6)		1990	2000	2010	2020	2030	2040	2050	2070	2100	
Life	[×10 year]	3									
Building schedule	[year]	0.25									
Start	[year]										
Load factor	[%]	27.4	27.4	27.4	27.4	27.4	27.4	27.4	27.4	27.4	27.4
Invcost	[ECU/kWe]	817	1130	985	840	820	820	820	820	820	820
O&M costs	[ECU/kWe]	17	23	20	17	17	17	17	17	17	17
Resid	[GWe]	0.125	0.065	0	0	0	0	0	0	0	0
Boundlo	[GWe]	0.374	4	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Boundup	[GWe]	0.375	4.3	10.5	18.3	25.8	31.7	36.1	42	42	42
Ibondup	[GWe/10 year]	0.35	3.9	6.2	8.2	11.4	12.1	12.6	14.7	14.7	14.7

Table A.23 *Technical economic characteristics of Near-Shore Wind Energy*

Near shore wind energy (EW6)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	4								
Building schedule	[year]	1								
Start	[year]	2000								
Load factor	[%]	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8
Total capital cost (1)	[ECU/kWe]	1171								
IDC (2)	[ECU/kWe]	29								
Invcost (1+2)	[ECU/kWe]	1200	1930	1510	1340	1260	1220	1200	1200	1200
O&M cost	[ECU/kWe]	36	58	45	40	38	37	36	36	36
Boundlo	[GWe]		0.2	1.25	1.25	1.25	1.25	1.25	1.25	1.25
Boundup	[GWe]		0.215	2.5	5.75	8.45	10	11.3	12.5	12.5
Ibondup	[GWe/10 year]		0.215	2.3	3.2	3.2	3.2	3.2	3.2	3.2

 Table A.24 *Technical economic characteristics of Offshore Wind Energy*

Offshore wind energy (EW7)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	4								
Building schedule	[year]	4								
Start	[year]	2010								
Load factor	[%]	36.5		36.5	36.5	36.5	36.5	36.5	36.5	36.5
Total capital cost(1)	[ECU/kWe]	1373								
IDC (2)	[ECU/kWe]	141								
Invcost (1+2)	[ECU/kWe]	1513		1800	1630	1550	1515	1515	1515	1515
O&M cost	[ECU/kWe]	41		51	45	43	41	41	41	41
Boundup	[GWe]			3.25	14.7	34.7	58.5	84.2	112.5	112.5
Ibondup	[GWe/10 year]			3.25	11.45	20	23.6	29.15	30.6	30.6

Table A.25 *Technical economic characteristics of PV on Roofs, Northern Europe*

PV on roofs northern Europe (ES1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Latitude Amsterdam										
Life	[×10 year]	3								
Building schedule	[year]	0.25								
Start	[year]	2000								
Annual load factor	[%]	10.64	10.64	10.64	10.64	10.64	10.64	10.64	10.64	10.64
	[hours/year]	932	932	932	932	932	932	932	932	932
Winter day	[%]	7.14	7.14	7.14	7.14	7.14	7.14	7.14	7.14	7.14
Winter night	[%]									
Summer day	[%]	24.56	24.56	24.56	24.56	24.56	24.56	24.56	24.56	24.56
Summer night	[%]									
Intermediate day	[%]	16.12	16.12	16.12	16.12	16.12	16.12	16.12	16.12	16.12
Intermediate night	[%]									
Invcost	[ECU/kWe]	930	5000	1980	1525	1070	930	930	930	930
O&M cost	[ECU/kWe]	7.6	20.5	14.8	11.45	8.1	7.6	7.6	7.6	7.6
Boundlo	[GWe]		0.05							
Boundup	[GWe]		1	2.5	10	20	40	60	100	120
Ibondup	[GWe/10 year]		1	2.5	7.5	12.5	20	30	35	40

Table A.26 *Technical economic characteristics of PV on Roofs, Central Europe*

PV on roofs, Central Europe (ES3)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Latitude Lyon										
Life	[×10 year]	3								
Building schedule	[year]	0.25								
Start	[year]	2000								
Annual load factor	[%]	15	15	15	15	15	15	15	15	15
	[hours/year]	1314	1314	1314	1314	1314	1314	1314	1314	1314
Winter day	[%]	10.07	10.07	10.07	10.07	10.07	10.07	10.07	10.07	10.07
Winter night	[%]									
Summer day	[%]	34.59	34.59	34.59	34.59	34.59	34.59	34.59	34.59	34.59
Summer night	[%]									
Intermediate day	[%]	22.73	22.73	22.73	22.73	22.73	22.73	22.73	22.73	22.73
Intermediate night	[%]									
Invcost	[ECU/kWe]	930	5000	1980	1525	1070	930	930	930	930
O&M cost	[ECU/kWe]	7.6	20.5	14.8	11.45	8.1	7.6	7.6	7.6	7.6
Boundlo	[GWe]		0.15	0.15	0.15					
Boundup	[GWe]		1	5	15	37.5	70	100	140	180
Ibondup	[GWe/10 year]		1	5	10	25	37.5	40	50	60

Table A.27 *Technical economic characteristics of PV on Roofs, Southern Spain*

PV on roofs, southern spain (ES2)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Latitude Malaga										
Life	[×10 year]	3								
Building schedule	[year]	0.25								
Start	[year]	2000								
Annual load factor	[%]	19.4	19.4	19.4	19.4	19.4	19.4	19.4	19.4	19.4
	[hours/year]	1700	1700	1700	1700	1700	1700	1700	1700	1700
Winter day	[%]	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6
Winter night	[%]									
Summer day	[%]	42.7	42.7	42.7	42.7	42.7	42.7	42.7	42.7	42.7
Summer night	[%]									
Intermediate day	[%]	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2
Intermediate night	[%]									
Invcost	[ECU/kWe]	930	5000	1980	1525	1070	930	930	930	930
O&M cost	[ECU/kWe]	7.6	20.5	14.8	11.45	8.1	7.6	7.6	7.6	7.6
Boundlo	[GWe]		0.15	0.15	0.15					
Boundup	[GWe]		1	7.5	12.5	27.5	42.5	50	50	50
Ibondup	[GWe/10 year]		2	7.5	10	17.5	22.5	22.5	22.5	22.5

Table A.28 *Technical economic characteristics of PV on Roofs and Barren Land, Central Spain*

PV on roofs and barren land central spain (ES4)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Latitude Madrid										
Life	[×10 year]	3								
Building schedule	[year]	0.25								
Start	[year]	2000								
Annual load factor	[%]	18.26	18.25	18.25	18.25	18.25	18.25	18.25	18.25	18.25
	[hours/year]	1600	1600	1600	1600	1600	1600	1600	1600	1600
Winter day	[%]	14.65	14.65	14.65	14.65	14.65	14.65	14.65	14.65	14.65
Winter night	[%]									
Summer day	[%]	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1
Summer night	[%]									
Intermediate day	[%]	27.42	27.42	27.42	27.42	27.42	27.42	27.42	27.42	27.42
Intermediate night	[%]									
Invcost	[ECU/kWe]	962	5750	2750	1980	1525	1070	1070	1070	1070
O&M cost	[ECU/kWe]	7.6	22	16	12.5	9.2	8.7	8.7	8.7	8.7
Boundlo	[GWe]		0.05	0.05	0.05					
Boundup	[GWe]		1	2.5	7.5	22.5	45	67.5	115	125
Ibondup	[GWe/10 year]		2	2.5	5	15	25	27.5	50	50

Table A.29 *Technical economic characteristics of Solar Thermal Power Plant*

Solar thermal power plant (ES7)		1990	2000	2010	2020	2030	2040	2050	2070	2100	
Latitude Southern Spain											
Life	[×10 year]	4									
Building schedule	[year]	3									
Start	[year]	1990									
Annual load factor	[%]	25	25	25	25	25	25	25	25	25	
	[hours/year]	2190									
Winter day	[%]	15	15	15	15	15	15	15	15	15	
Winter night	[%]	0	0	0	0	0	0	0	0	0	
Summer day	[%]	75	75	75	75	75	75	75	75	75	
Summer night	[%]	0	0	0	0	0	0	0	0	0	
Intermediate day	[%]	30	30	30	30	30	30	30	30	30	
Intermediate night	[%]	0	0	0	0	0	0	0	0	0	
Capital cost (1)	[ECU/kWe]	2045									
IDC (2)	[ECU/kWe]	155									
Invcost (1+2)	[ECU/kWe]	2200	2700	2400	2260	2200	2200	2200	2200	2200	
O&M cost	[ECU/kWe]	25	30	29	28	27	26	25	25	25	
Boundlo	[GWe]	0.05		0.05	0.05	0.05	0				
Boundup	[GWe]	0.055		0.25	0.5	1	2	3	4	5	
Iboundup	[GWe/10 year]	0.055		0.2	0.5	1	1.25	1.25	1.25	1.25	

Table A.30 *Technical economic characteristics of Archimedes Wave Swing*

Archimedes wave swing (EH3)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Wave power, Portugal and Ireland										
Life	[×10 year]	3								
Building schedule	[year]	2								
Start	[year]	2000								
Annual load factor	[%]	50	50	50	50	50	50	50	50	50
	[hours/year]	4380								
Winter day	[%]	60	60	60	60	60	60	60	60	60
Winter night	[%]	60	60	60	60	60	60	60	60	60
Summer day	[%]	40	40	40	40	40	40	40	40	40
Summer night	[%]	40	40	40	40	40	40	40	40	40
Intermediate day	[%]	50	50	50	50	50	50	50	50	50
Intermediate night	[%]	50	50	50	50	50	50	50	50	50
Capital cost (1)	[ECU/kWe]	1538								
IDC (2)	[ECU/kWe]	77								
Invcost (1+2)	[ECU/kWe]	1615	1800	1700	1650	1630	1615	1615	1615	1615
O&M cost	[ECU/kWe]	72	80	77	74	72	70	70	70	70
Boundlo	[GWe]		0.008	0.008	0.008	0				
Boundup	[GWe]		0.04	0.5	1.2	2.4	3.6	4	4	4
Ibondup	[GWe/10 year]		0.04	0.46	0.7	1.25	1.3	1.35	1.35	1.35

Table A.31 *Technical economic characteristics of Tidal Energy*

Tidal energy (EH4)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	6								
Building schedule	[year]	8.5								
Start	[year]	2010								
Annual factor	[%]	23		23	23	23	23	23	23	23
	[hours/year]	2015								
Winter day	[%]	24.5		24.5	24.5	24.5	24.5	24.5	24.5	24.5
Winter night	[%]	20		20	20	20	20	20	20	20
Summer day	[%]	24.5		24.5	24.5	24.5	24.5	24.5	24.5	24.5
Summer night	[%]	20		20	20	20	20	20	20	20
Intermediate day	[%]	24.5		24.5	24.5	24.5	24.5	24.5	24.5	24.5
Intermediate night	[%]	20		20	20	20	20	20	20	20
Capital cost (1)	[ECU/kWe]	1442								
IDC (2)	[ECU/kWe]	332								
Invcost (1+2)	[ECU/kWe]	1775		1775	1775	1775	1775	1775	1775	1775
O&M Cost	[ECU/kWe]	34		34	34	34	34	34	34	34
Boundlo	[GWe]	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24
Boundup	[GWe]	0.245	0.245	1.04	9.68	9.68	9.68	9.68	9.68	9.68
Ibondup	[GWe/10 year]	0	0	0.8	8.64	8.64	8.64	8.64	8.64	8.64

Table A.32 *Technical economic characteristics of Geothermal Power*

Geothermal power (ET1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	4								
Start	[year]									
Eff	[%]	15	15	15	15	15	15	15	15	15
Annual load factor	[%]	70								
Capital cost (1)	[ECU/kWe]	1000								
IDC (2)	[ECU/kWe]	103								
Invcost (1+2)	[ECU/kWe]	1103	1100	1100	1100	1100	1100	1100	1100	1100
O&M cost	[ECU/kWe]	26	26	26	26	26	26	26	26	26
Boundlo	[GWe]	0.54	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61
Boundup	[GWe]	0.55	0.7	1	1.6	1.6	1.6	1.6	1.6	1.6
Iboundup	[GWe/10 year]		0.15	0.3	0.6	0.6	0.6	0.6	0.6	0.6

 Table A.33 *Technical economic characteristics of Waste-To-Energy Power*

Wast-to-energy power (EI1)		1990	2000	2010	2020	2030	2040	2050	2070	2100
Life	[×10 year]	3								
Building schedule	[year]	3								
Start	[year]									
Eff	[%]	22.5	24	26	28	29	30	30	30	30
Annual load factor	[%]	75								
Capital cost (1)	[ECU/kWe]	8150								
IDC (2)	[ECU/kWe]	619								
Invcost (1+2)	[ECU/kWe]	8769	11000	9750	9180	8900	8770	8770	8770	8770
O&M cost	[ECU/kWe]	67	85	77	72	69	67	67	67	67
Boundlo	[GWe]	0.565	1.5	2.1	2.55	3.05	3.55	3.55	3.55	3.55
Boundup	[GWe]	0.575	1.9	2.75	4	5.25	6.25	6.25	6.25	6.25

ANNEX B BACKGROUND DATA ON IMPORTANT POWER GENERATION OPTIONS

Annex B gives background information on a few important power generation options, notably fission power, fusion power, lignite-fired power, and coal-fired power.

Table B.1 *Basic data with respect to investment cost of Fission Power*

	Type of LWR			PWR	PWR	PWR	PWR	Ref. PWR	Notes
	Type of PWR			Konvoi	Konvoi	Konvoi	N4		
	Reactor			KKI-2	KKE	GKN-2			
	Commissioned	JS		1988	1988	1989	(1992)		
	Rated power (net)	RP	[MWe]	1365	1290	1269	1390	1330	Konvoi reactors have been uprated
	Construction schedule	CS	[year]	5.6	5.8	6.2	6.23	6	6
	Inv. cost incl. of IDC	INV	[million DM88]	4448	4273	5080			(**) J.G. Kim, 1991, page 50
I	Construction cost	CC	[DM88/kWe]	2586	2608	3100			$1/(1.086)^{**}(CS/2)^{**}/RP*1000$
II	exclusive of first core		[ECU95/kWe]	1546	1559	1825		1643	$((1+INFL)^{**7}) * DM_NLG/ECU_NLG * CC$
III	Construction cost		[Bfr92/kWe]				65149		
IV	inclusive of first core		[ECU95/kWe]				1782		$((1+INFL)^{**3}) * BFR_NLG/ECU_NLG * CC$
V	Interest during constr.	IDC	[DM88/kWe]	379	396	506			$((1+DR)^{**}(CS/2) - 1) * CC$
VI	Discount rate 5%	Disc. Rate 5%	[Bfr92/kWe]				10693		
VII			[ECU95/kWe]	226	237	298	292	263	268
VIII			[DM88/kWe]	622	652	835			
IX	Discount rate 8%	Disc. Rate 8%	[Bfr92/kWe]				17650		
XI			[DM88/kWe]	791	830	1066			
XII	Discount rate 10%	Disc. Rate 10%	[Bfr92/kWe]				22520		
XIII			[ECU95/kWe]	473	496	637	616	555	563
	First core	FC	[million DM88]	225	191	175			J.G. Kim, 1991, page 50
XIV			[DM88/kWe]	165	148	138			FC/RP×1000
XV			[ECU95/kWe]	99	88	81		89	89
XV=I+V+XIV	Investment cost	Disc. Rate 5%	[DM88/kWe]	3130	3152	3744			SUM(CC+IDC+FC)
DM95/NLG95	1.1202	BFR95/NLG95	0.0544	Average deflation capital goods		0.015			

Continuation of Table B.1			KKI-2	KKE	GKN-2	N4	Ref.PWR	Notes	
XVI		[Bfr92/kWe]				83360		SUM(CC+IDC)+GC_SIM	
XVII=II+VII+XV		[ECU95/kWe]	1871	1884	2205	2280	2060	2057	N4 would have somewhat lower cost than ECU 2280/kWe (2074), excl. of connection to grid and simulator cost
XV=I+VIII+XIV	Disc. rate 8%	[DM88/kWe]	3373	3408	4073				
XVI		[Bfr92/kWe]				90317			
XVII=II+X+XV		[ECU95/kWe]	2016	2037	2406	2470	2232	2231	N4 would have cost ECU 2264/kWe, excl. of connection to grid and simulator cost
XVIII=I+XI+XIV	Disc. rate 10%	[DM88/kWe]	3542	3586	4303				
XIX		[Bfr92/kWe]				95187			
XX(=II+XIII+XV)		[ECU95/kWe]	2117	2143	2543	2603	2352	2352	N4 would have cost ECU 2398/kWe, excl. of connection to grid and simulator cost
	Decommissioning cost	Disc. rate 5%	[ECU95/kWe]					29	Based on publication (G. Frederick et al) on N4 cost $1/((1+DR)**LIFE)*DEC_FAC*CC$
DEC_FAC =	0.12	Disc. rate 8%	[ECU95/kWe]					9	
LIFE	40	Disc. rate 10%	[ECU95/kWe]					5	

Table B.2 *Basic data with respect to investment cost of Fusion Power*

Type of reactor Denomination	Tokamak	ITER								Note	
		DEMO RS (Fe1.0)		Commercial stage RS (Fe1.0)		DEMO	Commercial Single reactor	Commercial Twin reactor	Commercial Twin reactor		
Commissioned (year)	JS	2011	2020	2050	2070	2020	2050	2070	2100		
Structural material		Fe	Fe	V	V	Fe	V	V	V		
Coolant		water	water	helium	helium	water	helium	helium	helium		
Total thermal power		[MWth]	3239	2431	3239	3239	2431	3646,5	3646,5		
Fusion power	RPG	[MWth]	2879	2160	3110	2879	2160	3240	3240		
Rated power (net)	RP	[MWe]	1000	1000	1500	1000	1000	1500	1500		
Net efficiency		[%]	34,7	46,3	46,3	34,7	46,3	46,3	46,3	RP/RPG*100	
Construction schedule	CS	[year]	8	7	6,25	6,25	7	6,25	6,25		
I Fusion core	FC	[million ECU95]	3871				5314	2932	1296	1202	
Balance of plant	BOP						2592	2288	1383	1374	
VI=IV+V Total construction cost	TCC	[ECU/kWe]					7906	5220	2926	2576	TCC=FC+BOP
Interest during constr.	IDC										
VII	Disc. rate 5%	[ECU/kWe]					1472	860	482	424	
VIII	Disc. rate 8%	[ECU/kWe]					2444	1419	796	700	
IX	Disc. rate 10%	[ECU/kWe]					3130	1811	1015	894	
X=VI+VII Investment cost	Disc. rate 5%	[ECU/kWe]					9378	6080	3408	3000	
XI=VI+VIII	Disc. rate 8%	[ECU/kWe]					10350	6639	3722	3276	
XII=VI+IX	Disc. rate 10%	[ECU/kWe]					11036	7031	3941	3470	

Fusion power(EN1) \$93/ECU93 0,8571 Average deflation capital goods 0.015

References P.V. Gilli, R. Kurz: Fusion power as an additional vector in the IASA-WEC world scenarios (1998)

K. Tokimatsu: quantitative analysis of economy and environmental adaptability of Tokamak fusion power reactors. Thesis Univ. of Tokyo, December 19, 1997

T.C. Hendler, P.C. Knight, I. Cook: Fusion Economics, UKAEA FUS 333, UKAEA Fusion, Culham (1996)

P.J. Knight, I. Cook: Draft final report on fusion electricity costs, scalings and uncertainties, UKAEA Fusion, Culham (1998)

Table B.3 *Basic data with respect to investment cost of Pulverised Coal Fired Power Plant*

Type of power plant				Coal fired Supercritical Rostock	Coal fired Supercritical Elsdorf	Coal fired Supercritical/ultrasupercritical				
Site										
	Commissioned (year)	JS		1994	2004	2000	2010	2020	2030	2100
	Rated power (net)	RP	[MWe]	500	500					
	Construction schedule	CS	[year]	3,25	3,25	3,25	3,25	3,25	3,25	3,25
	Net efficiency			42,5	46	46	48	49	50	50
I	Inv. cost incl. of IDC	INV	[million DM]	1300	1200					
II			[DM95/kWe]	2639	2330					
III			[ECU95/kWe]	1422	1256					
IV	Construction cost	CC	[DM95/kWe]	2308	2071					
V	excl. of IDC		[ECU95/kWe]	1244	1116	1100	1100	1100	1100	1100
VI	IDC	IDC	[DM95/kWe]	190	171					
VII		Disc. rate 5%	[ECU95/kWe]	103	92	91	91	91	91	91
VIII		Disc. rate 8%	[DM95/kWe]	307	276					
IX			[ECU95/kWe]	166	149	147	147	147	147	147
X		Disc. rate 10%	[DM95/kWe]	387	347					
XI			[ECU95/kWe]	208	187	184	184	184	184	184
XII=IV+VI	Investment cost	Disc. rate 5%	[DM95/kWe]	2498	2242					
XIII=V+VII			[ECU95/kWe]	1347	1209	1191	1191	1191	1191	1191
XIV=IV+VIII		Disc. rate 8%	[DM95/kWe]	2615	2347					
XV=V+IX			[ECU95/kWe]	1410	1265	1247	1247	1247	1247	1247
XVI=IV+X		Disc. rate 10%	[DM95/kWe]	2695	2418					
XVII=V+XI			[ECU95/kWe]	1452	1303	1284	1284	1284	1284	1284

EC4 Reference coal fired power plant development 0.015 DM/95/ECU95 0.539

References G. Kolb, FZ Julich: Data tables for fossil power generation technologies.

K. Niehorster: Tendenzen bei fossilen Kraftwerken. Energiewirtschaft. Tagesfragen, March 1998, 164-166.

B. Stapper: Modern trends of hard coal based power generation in Germany. VEW Energie AG, Dortmund, Germany.

P. Ruhland: Modernes 500-Megawatt-Kraftwerk Rostock eingeweiht. Energiewirtschaft. Tagesfragen, November 1994, 726-727.

Energiewirtschaft. Tagesfragen, March 1997, 183-184.

Table B.4 Basic data with respect to investment cost of Lignite-Fired Power Plant

Type of power plant		Lignite fired 2×450 MWe	Lignite fired 400 MWe	Lignite fired 2×906 MWe	BoA 950 MWe	BoA	BoA-plus	BoA-plus	BoA-plus	BoA-plus	
Site		Schkopau	Altbach/Dieizisau	Lippendorf	Niederaussen						
	Commissioned (year)	JS	1996	1997	1998	2002	2000	2010	2020	2030	2100
	Rated power (net)	RP [MWe]	900	400	1812	950					
	Construction schedule	CS [year]	4	4	4	4	4	4	4	4	4
	Net efficiency		40	40	41	43	43	46	47,5	49	49
I	Inv. cost incl. of IDC	INV	[million DM]	2500	1300	5000	2300				
II			[DM95/kWe]	2737	3155	2639	2315				
III	Construction cost excl. of IDC	CC	[ECU95/kWe]	1475	1700	1422	1248				
IV			[DM95/kWe]	2390	2755	2305	2022				
V	IDC	IDC	[ECU95/kWe]	1288	1485	1242	1090	1142	1163	1185	1185
VI			[DM95/kWe]	245	282	236	207				
VII	Disc. rate 5%	Disc. rate 5%	[ECU95/kWe]	132	152	127	112	117	119	121	121
VIII			[DM95/kWe]	398	458	384	337				
IX	Disc. rate 8%	Disc. rate 8%	[ECU95/kWe]	214	247	207	181	190	194	197	197
X			[DM95/kWe]	502	579	484	425				
XI	Disc. rate 10%	Disc. rate 10%	[ECU95/kWe]	271	312	261	229	240	244	249	249
XII=IV+VI			[DM95/kWe]	2635	3038	2541	2230				
XIII=V+VII	Investment cost	Disc. rate 5%	[ECU95/kWe]	1420	1637	1370	1202	1259	1283	1306	1306
XIV=IV+VIII			[DM95/kWe]	2788	3214	2688	2359				
XV=V+IX	Disc. rate 8%	Disc. rate 8%	[ECU95/kWe]	1503	1732	1449	1271	1332	1357	1382	1382
XVI=IV+X			[DM95/kWe]	2892	3334	2789	2447				
XVII=V+XI	Decommissioning cost	Disc. rate 10%	[ECU95/kWe]	1559	1797	1503	1319	1382	1408	1434	1434
			[DM95/kWe]					7	7	7	7
							3	3	3	3	
							2	2	2	2	
EC6	DM95/ECU95	0.539	Average inflation capital goods	0.015	Reference lignite fired power plant development						
References	G. Kolb, FZ Julich: Data tables for fossil power generation technologies										
	J. Ewers et al: Braunkohlenförderung und -Verwendung. BWK, April 1998, 46-51										
	J. Ewers et al: Braunkohlenförderung und -Verwendung. BWK, April 1997, 47-53										
	Schkopau powers recovery with local lignite. Modern Power Systems, September 1996, Supplement, 21-25										
	W. Hlubek et al: Entwicklungslinien der Braunkohle-Kraftwerkstechnik. Energiewirtsch. Tagesfragen, September 1997, 512-519										
	BWK, July/August 1996, 21-22.										

ANNEX C LIST OF ENERGY CARRIERS/ MATERIALS TECHNOLOGIES AND DEMAND CATEGORIES IN MARKAL EUROPE 2.0

This annex presents an overview of the main constituents of the MARKAL-EUROPE 2.0 energy system model databases. As such, it provides an indication of the level of detail and comprehensiveness of the energy system modelled.

Subsequently, the following is listed (set symbol between brackets):

- 113 energy carriers and materials, representing the flows in the energy system network (set ENT in MARKAL),
- 536 technologies, subdivided into:
 - 46 conversion technologies producing electricity (set CON); the data for most of these technologies are presented in Annex A,
 - 154 conversion technologies producing other than electricity output (processes, set PRC),
 - 335 end-use technologies serving the useful energy demand (set DMD),
 - 51 useful energy demand categories (set DM).

All energy carriers/materials (total: 113)

CSV	Energy saving	FEQ	FOSSIL EQUALIVANT
BCE	Lignite for electricity generation	OLS	Oil shale
BCT	Total lignite (brown coal)	PCI	Petroleum coke for industry
BIT	Bitumina	PCK	Petroleum coke
CCO	Coking coal	PPH	Petroleum products for households
CCS	Coking coal for industry	SMW	Solid municipal waste
COA	Coal for agricultural sector	STW	Straw
COC	Coal for commercial sector	VRE	Vacuum residue
COE	Coal for electricity generation	WDH	Wood for households
COF	Coal for fuel conversion sector	WOD	Wood
COH	Coal for households	WOS	Wood for steel industry
COI	Coal for industry	HTS	High temperature steam
COK	Cokes	LTS	Low temperature steam
COR	Coke iron production	TEH	Total energy heat in residential sector
COS	Coal iron production	TET	Total energy heat
COT	Coal total primary	URA	uranium for power plant
COX	Fuel for IGCC power plant	GEO	Geothermal heat
COY	Coal for IG SOFC plant	SOL	Solar irradiation
DSL	Diesel	WAT	Hydro energy
DST	Diesel for transport sector	WDC	Wood chips
FOA	Residual fuel oil for agriculture	WIN	Wind energy
FOC	Residual fuel oil for commercial sector	ETH	Ethanol
FOE	Residual fuel oil for electricity	ETT	Ethanol for transport sector
FOI	Residual fuel oil for industry	GSS	Residual gas from steel industry
FOL	Residual fuel oil	HYL	Liquid hydrogen
FOT	Residual fuel oil for transport sector	MCB	Bricks
GAA	Gas for agricultural sector	MCC	Cement clinker
GAC	Gas for commercial sector	MET	Methanol
GAE	Gas for electricity generation	MIC	Chlorine
GAF	Gas for fuel conversion sector	MIF	Ammonia
GAH	Gas for households	MMA	Aluminium
GAI	Gas for industry	MMD	DRI quality steel
GAS	Natural gas	MMF	Direct Reduced Iron
GAX	Natural gas for STAG power plant	MMH	High quality hot rolled steel
GOA	Gas oil for agricultural sector	MMI	Iron
GOC	Gas oil for commercial sector	MML	Low quality hot rolled steel
GOI	Gas oil for industry	MMM	Medium quality hot rolled steel
GOL	Gas oil	MMS	High quality steel sheet
GSA	Gasoline for agricultural sector	MNP	Paper
GSI	Gasoline for industry	MNU	Pulp
GSL	Gasoline	MPE	Olefins
GST	Gasoline for transport sector	MPO	Polyolefins
HOE	Heavy oil products (PCK and BIT) for el	MPS	Styrene
HYD	Hydrogen	MTT	Methanol for transport sector
HYT	Hydrogen for transport sector	OLB	Biomass crude
KRI	Kerosene for industry	ORE	Iron ore
KRS	Kerosene	OXY	Oxygen
KRT	Kerosene for transport sector	PEL	Pellets
LPG	Liquified Petroleum Gas	RLC	Cold rolling steel dummy
LPI	LPG for industry	RLH	Hot rolling steel dummy
LPT	LPG for transport sector	SIN	Sinter
NAI	Naphtha for industry	WCC	Blast furnace slag
NAP	Naphtha	WMA	Waste aluminium
OLH	Heavy crude	WMF	Waste steel
STS	High temperature steam from steel ind.	WNP	Waste paper
TEC	Total energy heat in commercial sector	WPO	Waste polyolefins

Electricity production (total: 46)

	Fossil (24)		
Coal		Wind	
EC2	Existing pulverised coal fired p.p.	EW4	Large onshore wind turbine - inland
EC3	Existing lignite fired power plant		
EC4	New pulverised coal fired power plant	EW5	Large onshore wind turbine - shore
EC5	Integrated coal gasification p.p.		
EC6	New lignite fired power plant	EW6	Off-shore wind turbine - near shore
EC7	Integr. lignite power plant		
EC8	Integrated Coal Gasification SOFC plant	EW7	Off-shore wind turbine - off shore
ECA	Coal FBC CHP plant		
Oil			Storage (1)
ED0	Existing oil fired power plant	EH2	Hydro pumped storage
ED1	New oil fired power plant		
ED2	Oil gasification combined cycle p.p.		
Gas			
EG0	Existing gas fired power plant		
EG1	Gas turbine peaking plant		
EG2	Existing STAG power plant		
EG3	New STAG power plant		
EG4	Combined cycle SOFC power plant		
EGA	Existing gas turbine CHP plant		
EGB	Existing STAG CHP plant		
EGC	Exist. gas eng. gen. set for H,C and A		
EGD	New gas turbine CHP plant		
EGE	New STAG CHP plant		
EGF	New gas engine gen. set for H, C and A		
EGG	HERON SOFC total energy for H, C and A		
Waste			
EI1	Waste to energy plant (incinerator)		
	Nuclear (2)		
EN0	LWR power plant (fission)		
EN1	Fusion power plant		
	Renewable (19)		
Biomass			
BE1	Wood gasification:small industrial cog.		
BE2	Biomass gasifier:STAG power plant		
BE3	Biomass gasifier:ISTIG+reheat		
Hydro, wave, tidal			
EH0	Medium and high head hydro		
EH1	Low head hydro		
EH3	Archimedes Wave Swing		
EH4	TIDAL ENERGY		
Solar			
ES1	Solar PV in Northern Europe		
ES2	Solar PV roofs southern ESP, IT, GR		
ES3	Solar PV in Central Europe		
ES4	Solar PV roofs/barren land cent. ESP, IT		
ES5	Solar PV: import from North Africa		

ES6 SNAP energy tower in desert North.
Afr.
ES7 Solar thermal power plant in south.
ESP

Geothermal

ET1 geoThermal energy

Process Technologies (total: 154)

BB1	Biomass:briqu. plant	IPA	Polyolefin prod. polymerization
BC1	Biomass:wood chipping	IPB	Polyolefin prod. recycling
BF1	Biomass:methanol from straw	IRA	Ammonia prod. conventional
BP1	Biomass:diesel from rapeseed Middle	IRB	Ammonia prod. advanced
BP2	Biomass:ethanol from wheat Middle	IRC	Ammonia prod. conventional -CO2
BP3	Biomass:ethanol from sugarbeet Middle	IRD	Ammonia prod. advanced -CO2
BP4	Biomass:straw from miscanthus Middle	ITA	Styrene production Monsanto:Lummus Cres
BP5	Biomass:wood short rot. forests Middle	ITB	Styrene production catalytic membrane
BPA	Biomass:diesel from rapeseed South	IUA	Cement clinker dry process
BPB	Biomass:ethanol from wheat South	IUB	Cement clinker wet process
BPC	Biomass:ethanol from sugarbeet South	IUC	Cement clinker from blast furnace slag
BPD	Biomass:straw from miscanthus South	IVA	Paper production conventional
BPE	Biomass:wood short rot. forests South	IVB	Paper production impulse:cond. belt
GL1	Gas to liquids, mainly diesel	IVE	Mechanical pulp production
GL2	Gas to liquids, mainly kerosine	IVF	Chemical pulp production
IAA	Aluminium production Hall-Heroult	IVG	Recycling pulp production
IAB	Aluminium production inert anodes	OCR	Catalytic reformer
IAR	Aluminium production recycling	OFC	Fluid catalytic cracker
IBA	Brick production tunnel kiln	OFX	Flexi coker
IBB	Brick production roller kiln	OH1	Refinery heavy crude
ICA	Chlorine prod. membrane electr.	OHC	Hydrocracker
ICB	Chlorine prod. adv. membrane electr.	OHF	Hydrocracker for fuel oil
IGA	Iron prod. BF max coal inj.	OHY	Hycon
IGB	Iron prod. COREX	OL1	Refinery light crude
IGC	Iron prod. CCF	OVS	Visbreaker
IGD	Coke oven	SAT	Ethanol to transport sector
IGE	Sponge iron prod. DRI	SBA	Dummy ethanol to gasoline
IGF	Sponge iron prod. DRI -CO2	SBB	Dummy methanol to gasoline
IGG	Dummy cokes for iron production	SBE	Lignite to electricity generation
IGH	Dummy cokes for iron production -CO2	SBL	Dummy biocrude to light crude
IGI	Dummy coal for iron production	SCA	Coal to agricultural sector
IGJ	Dummy coal for iron production -CO2	SCC	Coal to commercial sector
IGK	Dummy residual gas from steel industry	SCE	Coal to electricity generation
IGL	Dummy residual steam from steel industr	SCF	Coal to fuel conversion sector
IGM	Dummy residual steam from steel ind. HP	SCH	Coal to households
IGN	Steel prod. hot rolling advanced	SCI	Coal to industry
IGO	Steel prod. cold rolling	SCM	Coal to methanol
IGP	Steel prod. hot rolling	SCS	Coking coal to industry
IGQ	Steel prod. BOF+additional scrap	SDT	Diesel to transport sector
IGR	Steel prod. scrap:EAF	SEH	Electrolysis (electricity to hydrogen)
IGS	Steel prod. BOF	SFA	Residual fuel oil to agricultural secto
IGT	Steel prod. DRI:EAF	SFC	Residual fuel oil to commercial sector
IGU	Sinter production	SFE	Residual fuel oil to electricity sector
IGV	Pellet production	SFH	Residual fuel oil to households
IGW	Dummy DRI steel to high quality	SFI	Residual fuel oil to industry
		SFT	Residual fuel oil to transport sector

Characterisation of power generation options

	steel		
IGX	Dummy mixing DRI:scrap based steel	SGA	Gas to agricultural sector
IGY	Dummy high to medium quality steel	SGC	Gas to commercial sector
IGZ	Dummy medium to low quality steel	SGE	Gas to electricity generation
IHA	Charcoal production for steel industry	SGF	Gas to fuel conversion sector
IHB	Dummy wood to coal:iron production	SGH	Gas to households
IHC	Dummy wood to coal:iron production - CO2	SGI	Gas to industry
IHD	Waste plastic for steel industry (extr.	SGM	Natural gas to methanol
INA	Petroch. Naphtha cracker	SHC	Total energy heat to commerce
INB	Petroch. Gas oil cracker	SHH	Total energy heat to households
INC	Petroch. Ethane cracker	SHL	Hydrogen (transport) to liquid hydrogen
IND	Petroch. Oxydative coupling	SHT	Hydrogen to transport sector
INE	Petroch. MTO	SHY	Hydrogen to households
INF	Petroch. LPG cracker		
SHZ	Hydrogen to commercial		
SIH	Dummy oil shale to Heavy crude		
SKT	Kerosene to transport sector		
SLI	LPG to industry		
SLT	LPG to transport sector		
SMT	Methanol to transport sector		
SNI	Naphtha to industry		
SOA	Gas oil to agricultural sector		
SOC	Gas oil to commercial sector		
SOH	Gas oil to households		
SOI	Gas oil to industry		
SOT	Gas oil to transport sector		
SPH	Petroleum products to households		
SPI	Petroleum coke to industry		
SRB	Dummy bitumina to oil for electricity		
SRF	Dummy petrocoke to oil for electricity		
SRM	Dummy gasoline to diesel		
SRN	Dummy diesel to kerosene		
SRO	Dummy kerosene to naphtha		
SRP	Dummy naphtha to gasoil		
SRQ	Dummy gasoil to residual fuel oil		
SRR	Dummy residual fuel oil to bitumen		
SSA	Gasoline to agricultural sector		
SSH	Gasoline to households		
SSI	Gasoline to industry		
SST	Gasoline to transport sector		
STH	Dummy high to low temperature steam		
STL	Dummy low temperature steam production		
SWH	Wood to households		
SZ1	Coal for IGCC plant (dummy)		
SZ2	Coal for IGCC plant with CO2 removal		
SZ3	Natural gas for STAG plant (dummy)		
SZ4	Natural gas STAG plant with CO2 removal		
SZ5	Nat.gas to hydrogen with CO2 removal		
SZ6	Coal to hydrogen with CO2 removal		
SZ7	Coal for IG SOFC plant (dummy)		
SZ8	Coal for IG SOFC plant with CO2 removal		
SZU	Oxygen production		

Demand (end-use) technologies (total: 335)

AD1	Dummy agricultural diesel demand	C2Q	TE heat+low e. (M.Euro, lg.off.)
AE1	Dummy agricultural electricity demand	C2R	TE heat+low e+heat rec.(M.Euro, lg.off.)
AG1	Dummy natural gas to agricultural secto	C30	Gas boiler (South Europe, comm.heat)
C00	Gas boiler (N. Europe, comm)	C31	Condensing gas boiler (S Europe, comm)
C01	Condensing gas boiler (N. Europe, comm)	C32	Cond.boil.low-e glass (S. Europe, comm)
C02	Cond.boil.low-e glass (N. Europe, comm)	C33	Cond.boil+low-e+heat recov.(S.Europe)
C03	Cond.boil+low-e+heat recov.(N.Europe)	C36	Oil boiler (South Europe comm. heat)
C06	Oil boiler (North Europe comm. heat)	C37	Oil boil+low-e (South Europe)
C07	Oil boil+low-e (North Europe)	C38	Oil.boil+low-e+heat recov.(South Europe)
C08	Oil.boil+low-e+heat recov.(North Europe)	C3A	Coal boiler (South Europe, comm. heat)
C0A	Coal boiler (North Europe, comm. heat)	C3B	Coal boil+low-e (S.Europe)
C0B	Coal boil+low-e (N.Europe)	C3C	Coal.boil+low-e+heat recov.(S.Europe)
C0C	Coal.boil+low-e+heat recov.(N.Europe)	C3E	Electric heatpump (South Europe)
C0E	Electric heatpump (North Europe)	C3F	El.heatpump+low-e glass (South Europe)
C0F	El.heatpump+low-e glass (North Europe)	C3G	Electric resistance:boiler(South Europe)
C0G	Electric resistance:boiler(North Europe)	C3H	El.resist+low-e glass (South Europe)
C0H	El.resist+low-e glass (North Europe)	C3I	El.resist+low-e+heat rec.(South Europe)
C0I	El.resist+low-e+heat rec.(North Europe)	CES	Other commercial electric appliances
C0K	District heat(North Europe, comm.heat)	I1A	Gas boiler:LTH:large industry
C0L	District heat+low emit.glass (N.Europe)	I1B	Fuel oil boiler:LTH:large industry
C0M	Dist.heat+l.em.gl.+heat rec.(N.Europe)	I1C	Coal boiler:LTH:large industry
C0P	TE heat(North Europe)	I1D	Hydrogen boiler:LTH:large industry
C0Q	TE heat+low e.glass (N. Europe)	I1E	Electric heatpump:LTH:large industry
C0R	TE heat+low e+heat rec.(N.Europe)	I1F	Heat exchanger:LTH:large industry
C10	Gas boiler (M.Euro, small office heat)	I2A	Gas burner:HTH:large industry
C11	Cond.gas boiler (M.Euro, small office)	I2B	Fuel oil burner:HTH:large industry
C12	Cond.boil.low-e glass (M.Eur,small off)	I2C	Coal burner:HTH:large industry
C13	Cond.boil+low-e+heat recov.(M.Eur,sm.of)	I2D	Hydrogen burner:HTH:large industry
C16	Oil boiler (M.Europe, small building)	I2E	Electric heating:HTH:large industry
C17	Oil boil+low-e (M.Europe, small build.)	I2F	LPG burner:HTH:large industry
C18	Oil.boil+low-e+heat recov.(M.Eur,sm.of)	I3A	Gas boiler:LTH:small industry
C1A	Coal boiler (M.Europe, small building)	I3B	Gas oil boiler:LTH:small industry
C1B	Coal boil+low-e (M.Europe, small build.)	I3C	Coal boiler:LTH:small industry
C1C	Coal.boil+low-e+heat recov.(M.Eur,sm.of)	I3D	Hydrogen boiler:LTH:small industry
C1E	Electric heatpump (M.Euro, small office)	I3E	Abs. heatpump:LTH:small industry
C1F	El.heatpump+low-e glass (M.Euro,	I3F	Compr. heatpump:LTH:small industry

Characterisation of power generation options

	sm.off		
C1K	District heat(M.Euro, small office heat	I3G	Electric heatpump:LTH:small industry
C1L	District heat+low emit.glass (M.Euro,SO	I3H	Heat exchanger:LTH:small industry
C1M	Dist.heat+l.em.gl.+heat rec.(M.Euro,SO)	I4A	Gas boiler:HTH:small industry
C1P	TE heat(M.Euro, small office heat)	I4B	Gas oil boiler:HTH:small industry
C1Q	TE heat+low e.glass (M.Euro, sm office)	I4T	Straw boiler:HTH:small industry
C1R	TE heat+low e+heat rec.(M.Euro, sm.off.	I4W	Wood boiler:HTH:small industry
C20	Gas boiler (M.Euro, large office heat)	I5A	El. appl.&light:ELE:large industry
C21	Cond.gas boiler (M.Euro, large office)	I5M	Electric drive:ELE:large industry
C22	Cond.boil.low-e glass (M.Eur,large off)	I5N	Adv. electric drive:ELE:large industry
C23	Cond.boil+low-e+heat recov.(M.Eur,lg.of	I6A	El. appl.&light:ELE:small industry
C26	Oil boiler (M.Europe, large building)	I6M	Electric drive:ELE:small industry
C27	Oil boil+low-e (M.Europe, large build.)	I6N	Adv. electric drive:ELE:small industry
C28	Oil.boil+low-e+heat recov.(M.Eur,lg.of)	IA0	Aluminium prod. dummy
C29	Coal boiler (M.Europe, large building)	IB0	Brick prod. dummy
C2B	Coal boil+low-e (M.Europe, large build.	IC0	Chlorine prod. Dummy
C2C	Coal.boil+low-e+heat recov.(M.Eur,lg.of	IG0	Steel prod. Dummy
C2G	Electric heatpump (M.Euro, large office	IP0	Olefin prod. Dummy
C2I	EL.heatpump+low-e glass (M.Euro, lg.off	IR0	Ammonia prod. Dummy
C2K	District heat(M.Euro, large office heat	IS0	Olefine demand excl. polyolefins
C2L	District heat+low emit.glass (M.Euro,LO	IT0	Styrene prod. dummy
C2M	Dist.heat+l.em.gl.+heat rec.(M.Euro,LO)	IU0	Cement clinker prod. dummy
C2M			
C2P	Total energy heat (M.Euro, large office	R4L	Coal stove
IV0	Paper:board prod. dummy	R4M	Wood stove
N1A	Dummy lubricants + bitumen	R5A	District heat exchanger
R1A	District heat exchanger	R5B	District heat+floor insul.+heat recov.
R1B	District heat+floor insul.+heat recov.	R5C	District heat + maximum insulation
R1C	Gas boiler	R5D	Conventional gas boiler
R1D	Condensing gas boiler	R5E	Condensing gas boiler
R1E	R1D + floor insulation	R5F	R5E + floor insulation
R1F	R1E + PU foam + heat recovery	R5G	R5F + heat recovery
R1G	R1F + coated glass	R5H	R5G + coated glass
R1H	R1F + coated and gasfilled glass	R5I	R5G + coated and gasfilled glass
R1I	R1F +3-double coated and gasfilled glas	R5J	R5G +3-double coated and gasfilled glas
R1J	Total energy heat	R5K	Electric heatpump: heat + water
R1K	R1J + floor insulation + heat recovery	R5L	R5K + floor insulation
R1L	R1J + maximum insulation	R5M	R5L + coated glass
R1M	Petroleum products	R5N	R5L + coated and gasfilled glass
R1N	Electric resistance	R5O	R5K + triple glass + impreg. wall insul
R1O	Coal stove	R5P	Total energy heat
R1P	Wood stove	R5Q	R5P + floor insulation + heat recovery

R1X	Electric heatpump North/SFD	R5R	R5P + maximum insulation	
R2A	District heat exchanger	R5S	Petroleum products	
R2B	R2A + coated glass	R5T	Electric resistance	
R2C	R2B + heat recovery	R5U	Coal stove	
R2D	District heat + maximum insulation	R5V	Wood stove	
R2E	Gas boiler	R6A	District heat exchanger	
R2F	Condensing gas boiler	R6B	District heat+floor insul.+heat recov.	
R2G	R2F + coated glass	R6C	Gas boiler	
R2H	R2G + heat recovery	R6D	Condensing gas boiler	
R2I	R2F + maximum insulation	R6E	R6D + floor insulation	
R2J	Petroleum products	R6F	R6E + PU foam + heat recovery	
R2K	Electric resistance	R6G	R6F + coated glass	
R2L	Coal stove	R6H	R6F + coated and gasfilled glass	
R2M	Wood stove	R6I	R6F +3-double coated and gasfilled glas	
R3A	District heat exchanger	R6J	Total energy heat	
R3B	District heat+floor insul.+heat recov.	R6K	R6J + floor insulation + heat recovery	
R3C	Gas boiler	R6L	R6J + maximum insulation	
R3D	Condensing gas boiler	R6M	Petroleum products	
R3E	R3D + floor insulation	R6N	Electric resistance	
R3F	R3E + PU foam + heat recovery	R6O	Coal stove	
R3G	R3F + coated glass	R6P	Wood stove	
R3H	R3F + coated and gasfilled glass	R6X	Electric heatpump South/SFD	
R3I	R3F +3-double coated and gasfilled glas	R7A	District heat exchanger	
R3J	Total energy heat	R7B	R7A + coated glass	
R3K	R3J + floor insulation + heat recovery	R7C	R7B + heat recovery	
R3L	R3J + maximum insulation	R7D	District heat + maximum insulation	
R3M	Petroleum products	R7E	Gas boiler	
R3N	Electric resistance	R7F	Condensing gas boiler	
R3O	Coal stove	R7G	R7F + coated glass	
R3P	Wood stove	R7H	R7G + heat recovery	
R3X	Electric heatpump Middle/SFD-existing	R7I	R7F + maximum insulation	
R4A	District heat exchanger	R7J	Petroleum products	
R4B	R4A + coated glass	R7K	Electric resistance	
R4C	R4B + heat recovery	R7L	Coal stove	
R4D	District heat + maximum insulation	R7M	Wood stove	
R4E	Gas boiler	RA1	Gas boiler water heater	
R4F	Condensing gas boiler	RA2	Combi boiler water heater	
R4G	R4F + coated glass	RA3	Electric water heater	
R4H	R4G + heat recovery	RA4	Electric heatpump boiler	
R4I	R4F + maximum insulation			
	R4J	Petroleum products	RA5	Petroleum products water heater
	R4K	Electric resistance	T05	Fuel Cell car with MF and RB
	RA6	Coal water heater	T06	Methanol car with MF and IIC
	RA7	Wood water heater	T07	Ethanol car with MF and IIC
	RA8	Solar boiler: electric heatpump backup	T08	Electric car mid term with MF and RB
	RA9	Solar boiler: gas backup	T09	Electric car long term with MF and RB
	RB1	Gas boiler water heater	T0A	Ethanol car with MF and partly IIC
	RB2	Combi boiler water heater	T0D	Diesel car standard
	RB3	Electric water heater	T0E	Electric car short term with MF and RB
	RB4	Electric heatpump boiler	T0F	Fuel Cell car with MF
	RB5	Petroleum products water heater	T0G	Gasoline car standard
	RB6	Coal water heater	T0M	Methanol car with MF and partly IIC
	RB7	Wood water heater	T11	Diesel van with IIC and MF
	RB8	Solar boiler: el.heatp.backup: ex.house	T12	Diesel van with IIC, MF and CVT
	RB9	Solar boiler: gas backup: existing hous	T13	Gasoline van with IIC and MF

RBA	Solar boiler: el.heatp.backup: new hous	T14	Gasoline van with IIC, MF and CVT
RBB	Solar boiler: gas backup: new house	T15	Fuel Cell van with MF and RB
RC1	Gas boiler water heater	T16	Electric van mid term with MF and RB
RC2	Combi boiler water heater	T17	Electric van long term with MF and RB
RC3	Electric water heater	T18	Hybrid van with MF, RB and CVT
RC4	Electric heatpump boiler	T1D	Diesel van standard
RC5	Petroleum products water heater	T1E	Electric van short term with MF and RB
RC6	Coal water heater	T1F	Fuel Cell van with MF
RC7	Wood water heater	T1G	Gasoline van
RC8	Solar boiler: electric heatpump backup	T1H	Hybrid van with MF and RB
RC9	Solar boiler: gas backup	T21	Diesel truck with IIC
RD1	Conventional dishwasher	T22	Diesel truck with IIC and MF
RD2	Dishwasher (enzymatic detergent)	T23	Fuel Cell Truck with MF and RB
RD3	Dishwasher (enzym.: ASD: optical sensor	T2D	Diesel truck standard
RES	Other existing electric appliances	T2F	Fuel Cell Truck with MF
RF1	Gas cooker	T2M	Methanol Truck with MF and IIC
RF2	Electric cooker	T31	Diesel bus with MF and IIC
RF3	Infrared jet impingement cooker	T32	Diesel bus with MF, IIC and CVT
RF4	Petroleum product cooker	T33	Electric bus long term with MF and RB
RF5	Coal cooker	T3D	Diesel bus standard
RF6	Wood cooker	T3E	Electric bus mid term with MF and RB
RL1	Incandescent lamp residential	T3F	Fuel Cell bus with MF and RB
RL2	Halogen lamp residential	T4D	Diesel rail transport
RL3	Fluorescent lamp residential	T4E	Electric rail transport
RLA	PL:SL lamp (>350 hours:year)	T5D	Diesel inland ships
RLB	PL:SL lamp (300-350 hours:year)	T5F	Hydrogen inland ships
RLC	PL:SL lamp (200-300 hours:year)	T6H	Hydrogen aircraft
RNS	Other new electric appliances	T6K	Kerosene aircraft
RR1	Old type refrigerator	T71	Dummy bunker demand
RR2	Standard refrigerator (3 cm insulation)	T04	Diesel car with MF and IIC
RR3	Better insulated absorption refrigerator	T03	Diesel car with MF and partly IIC
RR4	Improved absorption refrigerator		
RR5	Stirling refrigerator (krypton panels)		
RR6	Stirling refrigerator (soft vac. panels		
RT1	Tumble drier (conventional)		
RT2	Tumble drier (improved)		
RT3	Heat pump drier (improved)		
RT4	Tumble drier (improved: high speed spin		
RT5	Heat pump drier (impr.: high speed spin		
RW1	Conventional washing machine		
RW2	Washing machine (ASD: optical sensor)		
T01	Gasoline car with MF and partly IIC		
T02	Gasoline car with MF and IIC		

Demand categories (total: 51)

AD	Agricultural diesel demand
AE	Agricultural electricity demand
AG	Natural gas to agricultural sector
C0	North Eur. service sect. space heat
C1	Middle Eur. service sect. small buildin

C2	Middle Eur. service sect. large buildin
C3	South Eur. service sect. space heat
CE	Commercial other electricity demand
I1	LTH large industry
I2	HTH large industry
I3	LTH small industry
I4	HTH small industry
I5	ELE large industry
I6	ELE small industry
IA	Aluminium
IB	Bricks
IC	Chlorine
IG	Steel
IP	Polyolefine
IR	Ammonia
IS	Olefine
IT	Styrene
IU	Cement clinker
IV	Paper
N1	Non Energy Use: Lubricants+Bitumen
R1	Space heating:SFD - North Europe
R2	Space heating:MFD - North Europe
R3	Space heating:SFD - Middle Europe
R4	Space heating:MFD - Middle Europe
R5	Space heating:NEW - Middle Europe
R6	Space heating:SFD - South Europe
R7	Space heating:MFD - South Europe
RA	Water heating - North Europe
RB	Water heating - Middle Europe
RC	Water heating - South Europe
RD	Dishwashers
RE	Other existing electric appliances
RF	Food preparation
RL	Lighting
RN	Other new electric appliances
RR	Refrigerators and freezers
RT	Tumble driers
RW	Washing machines
T0	Passenger car
T1	Van
T2	Truck
T3	Bus
T4	Rail Transport
T5	Water Transport Inland
T6	Air Transport
T7	Bunkers

REFERENCES

- [1] P. Lako, J.R. Ybema, A.J. Seebregts: *The long term potential of fusion power in Western Europe*. ECN-C--98-071, Petten 1998.
- [2] J.-G. Kim: *Wirtschaftlichkeitsanalyse der in der Bundesrepublik Deutschlands gebauten Kernkraftwerke und Vergleich mit Steinkohlekraftwerken*. Universität Essen, February 1991.
- [3] G. Frederic et al: *Competitiveness of nuclear power in Belgium*. In: 'The nuclear power option', Proceedings of an International Conference, Vienna, 5-8 September 1994, IAEA, Vienna, 1995, 505-523.
- [4] G. Kolb: *Review and revision of existing relevant studies. Part B, Data tables for nuclear, fossil and renewable technologies, etc*. FZ Jülich, July 1998.
- [5] H.N. Schludi: *Risiken bei Kernkraftwerken und deren Versicherung*. BWK, March 1994, 95-100.
- [6] P. Lako et al: *Economics and market potential of the modular High Temperature Reactor in the Netherlands*. ECN, April 1995, ECN-R--95-012.
- [7] P.V. Gilli, R. Kurz: *Fusion power as an additional vector in the IIASA-WEC world scenarios*. Arge Wärmetechnik, Graz (Austria), October 1998.
- [8] P.C. Rühland: *Modernes 500-Megawatt Kraftwerk Rostock eingeweiht*. *Energiewirtschaftliche Tagesfragen*, 11, 1994, 726-727.
- [9] *Energiewirtschaftliche Tagesfragen*, 3, 1997, 183-184.
- [10] P.T. Alderliesten, et al: *An attractive option for CO₂ control in IGCC systems: water gas shift with integrated H₂/CO₂ separation (WIHYS) process. PHASE I: proof of principle*. CEC project JOU2 CT92-0158.
- [11] J. Ewers et al: *Braunkohlenförderung und Verwendung*. BWK, April 1998, 46-51.
- [12] J. Ewers et al: *Braunkohlenförderung und Verwendung*. BWK, April 1997, 47-53.
- [13] *Schkopau powers recovery with local lignite*. *Modern Power Systems*, September 1996, Supplement, 21-25.
- [14] W. Hubek, et al: *Entwicklungslinien der Braunkohle-Kraftwerkstechnik*. *Energiewirtschaftliche Tagesfragen*, September 1996, 512-519.
- [15] BWK, July/August 1996, 21-22.
- [16] P. Lako, J.R. Ybema: *CO₂ abatement in Western European power generation*. ECN, May 1997, ECN-C--97-053, 61-69.
- [17] J.R. Ybema, et al: *Prospects for energy technologies in the Netherlands. Volume 2*. ECN, August 1995, ECN-C--95-039, 25-33.
- [18] D.J. Gielen, et al: *Prospects for bioenergy in the Netherlands*. ECN-C--97-103, Petten, 1998.
- [19] P. Lako, et al: *European biomass scenarios and the need for import of biomass*. ECN-R--97-009, Petten, 1997.
- [20] *Energie & Milieuspectrum*, March 1996, 27.
- [21] *An assessment of renewable energy in the UK*. ETSU, Harwell, 1994.
- [22] P. Breeze: *Power generation technologies*. Financial Times Energy, 1998.
- [23] G. Bordy: *Geothermal systems applied to power generation*. PowerGen '96, 24-28 June 1996, Budapest, Volume II, 723-737.
- [24] P. Ungemach: *An overview of the state of geothermal energy*. Int. J. of Energy Research, July/Sept. 1985, 223-228.

- [25] De huisvuilcentrale N-H; *schets van een moderne afvalverbrandingsinstallatie met rookgasreiniging en energie-opwekking*. Alkmaar, 1995.